

**Failure to Submit a Disinfectant Level Quarterly Operating Report (DLQOR)  
MONITORING, ROUTINE (DBP), MAJOR/CHLORINE**

The CITY OF RISING STAR water system PWS ID 0670005 has violated the monitoring/reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

This violation occurred in the monitoring period fourth quarter of 2019.

We are taking the following actions to address this issue:

Report the DISINFECTANT LEVEL QUARTERLY OPERATING REPORT (DLQOR) on time each quarter.

If you have questions regarding this matter, you may contact City of Rising Star at 254-643-4261.

Posted/Delivered on: 3.12.2020